

MAYOR JIM GRAY



**LEXINGTON**

TODD SLATIN  
DIRECTOR  
CENTRAL PURCHASING

**ADDENDUM #7**

Bid Number: #106-2017

Date: September 19, 2017

Subject: Expansion Area 3 Pump Station (Contract 1) and Force Main  
(Contract 2) Improvements

Address inquiries to:  
Brian Marcum  
(859) 258-3320

**TO ALL PROSPECTIVE SUBMITTERS:**

**Please be advised of the following clarifications to the above referenced bid:**

The odor control ductwork is PVC, as shown on the drawings, and FRP as specified in 15892 added in Addendum#6. The material for the ductwork, dampers and transition pieces can be either PVC or FRP.

Todd Slatin, Director  
Division of Central Purchasing

All other terms and conditions of the bid and specifications are unchanged. This letter should be signed, attached to and become a part of your submittal.

COMPANY NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

SIGNATURE OF BIDDER: \_\_\_\_\_

