

CITY OF CADIZ, KENTUCKY

**WATER TREATMENT PLANT
(WMS #15171)**

ADDENDUM NO. SIX TO THE CONTRACT DOCUMENTS

VOLUME I – CONTRACT SPECIFICATIONS

The following additions and modifications shall be made to the CONTRACT SPECIFICATIONS:

1. PROPOSAL

- (a.) On page 1 of the Bid Form, revise Paragraph 2.01 to read as follows:

“... remain subject to acceptance for 90 days after bid opening...”

2. SPECIAL CONDITIONS

- (a.) Add Paragraph 27 to read as follows:

“27. Chemical Purchases

The Owner shall be responsible for the purchase of chemicals for filling the bulk storage tanks and purchase of chemical totes for the startup and operation of the treatment plant. Miscellaneous chemicals required as part of any startup testing, pilot testing, or construction related activities shall be provided by the contractor.”

3. SECTION 11B

- (a.) Add the following to Paragraph 1.01:

“B. Provide fiberglass gratings in chemical storage areas.”

4. SECTION 11C

- (a.) Add the following to Paragraph 1.01:

“C. Provide fiberglass railings in chemical storage areas.”

9. SECTION 18E

- (a.) Revise Paragraph 1.1 to read as follows:

“... by Pall, Suez, Memcor, or equal.”

- (b.) Revise Paragraph 1.1 to add the following Paragraph:

“The naming of equipment manufacturers does not indicate pre-approval of any design or facility layout. All equipment manufacturers shall supply the equipment listed in this specification and shown on the contract drawings along with all other components required to provide a fully operational filtration system, and the general layout of the facilities shall conform to the layout as shown on the contract drawings.”

5. SECTION 22A

- (a.) Revise the Pump Schedule for the High Service Pumps as follows:

“Secondary TDH – 110 Ft”

5. SECTION 22A

- (a.) Revise the Pump Schedule for the Raw Water Pumps as follows:

“Representative Model No. Fairbanks Morse 18H – 3 Stage”

6. SECTION 22E

(a.) Revise Paragraph 2.1 to read as follows:

"Sump pumps shall be 50 gpm at 25 TDH, 0.75 HP, 1750 RPM, 480 V, 3P, 60 Hz."

VOLUME II – CONTRACT DRAWINGS

The following additions and modifications shall be made to the CONTRACT DRAWINGS:

1. Sheet P-15

(a.) Add the following note to read as follows:

"10. Provide and install a 24" butterfly valve for isolation of the check valve and pump."

2. Sheet E-4

(a.) Revise the clarifier control panel note to read as follows:

"Scraper arm drive mounted to handrail"

(b.) Revise Electrical Keynote 1 to read as follows:

"Provide Hand-Off-Auto switch, "Run" Light, "Fault" Light, push button alarm resets, and electrical disconnect as part of the panel enclosure."

WATER MANAGEMENT SERVICES, LLC
Consulting Engineers

By: Steven M. Jones
Steven M. Jones
License No. 26233

Dated: May 10, 2018

Company Name

Signature

Date

Please acknowledge receipt of this Addendum by signing below and emailing or faxing this page back to Water Management Services, LLC at 615/366-6203. Thank you.